

WRIS Asset Inventory Report

KY0022934 - Leitchfield Utilities Commission

Rating Code	Condition Rating	Performance Rating	Priority Rating
0			Not a priority
1	New or Excellent - None or minor defects.	Exceeds/Meets all performance targets.	It would be nice to have.
2	Good - Defects that have not begun to deteriorate.	Minor performance deficiencies.	Improved system operations & maintenance (O&M) efficiency.
3	Fair - Moderate defects that will continue to deteriorate.	Considerable performance deficiencies.	Internal safety concern or public nuisance.
4	Poor - Severe defects that will collapse/break in near future.	Major performance deficiencies.	Potential public health, safety, or environmental concern.
5	Inoperable - Defects need immediate attention.	Fails to meet performance targets.	Existing threat to public health, safety, or environment.

Sewer Line Assets

Size (inches)	Type	Material	Decade Constructed	Length (feet)	Condition ID	Performance ID	Priority ID	WRIS PNum
Assessment Area: CENTRAL								
6	Force	PVC	1950	8,511				
8	Gravity	PVC	1950	21,878				
10	Gravity	PVC	1950	379				
12	Gravity	PVC	1950	2,907				
Assessment Area: DOWNTOWN								
4	Force	PVC	1950	3,957				
4	Force	PVC	2010	1,616				
6	Gravity	PVC	1950	2,986				
6	Force	PVC	2010	55				
8	Gravity	PVC	1950	58,828				
8	Gravity	PVC	2010	378				
10	Gravity	PVC	1950	1,908				
12	Gravity	PVC	1950	8,371				
15	Gravity	PVC	1950	48				
18	Gravity	PVC	1950	4,583				
21	Gravity	PVC	1950	1,082				
Assessment Area: EAST								
4	Force	PVC	1950	3,041				
4	Force	PVC	2000	4,490				
6	Force	PVC	2010	2,790				
8	Gravity	PVC	1950	3,795				
8	Gravity	PVC	2000	1,113				
8	Gravity	PVC	2010	1,403				
Assessment Area: NORTH								
4	Force	PVC	2000	3,345				
8	Force	PVC	1950	11,212				
8	Gravity	PVC	2000	5,210				
Assessment Area: RESIDENTIAL								
4	Force	PVC	1950	4,772				
6	Force	PVC	1950	2,691				
8	Gravity	PVC	1950	92,337				
10	Gravity	PVC	1950	2,106				
12	Gravity	PVC	1950	2,232				
18	Gravity	PVC	1950	1,497				

WRIS Asset Inventory Report

KY0022934 - Leitchfield Utilities Commission

Rating Code	Condition Rating	Performance Rating	Priority Rating
0			Not a priority
1	New or Excellent - None or minor defects.	Exceeds/Meets all performance targets.	It would be nice to have.
2	Good - Defects that have not begun to deteriorate.	Minor performance deficiencies.	Improved system operations & maintenance (O&M) efficiency.
3	Fair - Moderate defects that will continue to deteriorate.	Considerable performance deficiencies.	Internal safety concern or public nuisance.
4	Poor - Severe defects that will collapse/break in near future.	Major performance deficiencies.	Potential public health, safety, or environmental concern.
5	Inoperable - Defects need immediate attention.	Fails to meet performance targets.	Existing threat to public health, safety, or environment.

Sewer Line Assets

Size (inches)	Type	Material	Decade Constructed	Length (feet)	Condition ID	Performance ID	Priority ID	WRIS PNum
Assessment Area: SOUTHWEST								
4	Force	PVC	2010	87				
6	Gravity	PVC	2010	11,913				
Assessment Area: STP								
8	Gravity	PVC	1950	5,861				
24	Gravity	PVC	1950	2,045				
Assessment Area: WEST								
4	Force	PVC	1950	2,550				
8	Gravity	PVC	Prior to 1950	1,860				
8	Force	PVC	1950	19,975				
12	Gravity	PVC	1950	815				

WRIS Asset Inventory Report

KY0022934 - Leitchfield Utilities Commission

Rating Code	Condition Rating	Performance Rating	Priority Rating
0			Not a priority
1	New or Excellent - None or minor defects.	Exceeds/Meets all performance targets.	It would be nice to have.
2	Good - Defects that have not begun to deteriorate.	Minor performance deficiencies.	Improved system operations & maintenance (O&M) efficiency.
3	Fair - Moderate defects that will continue to deteriorate.	Considerable performance deficiencies.	Internal safety concern or public nuisance.
4	Poor - Severe defects that will collapse/break in near future.	Major performance deficiencies.	Potential public health, safety, or environmental concern.
5	Inoperable - Defects need immediate attention.	Fails to meet performance targets.	Existing threat to public health, safety, or environment.

Lift Station Assets

Asset Name	Date of Last Maintenance	Date of Next Maintenance	Capacity (GPM)	Pump Count	Condition ID	Performance ID	Priority ID	WRIS PNum
Assessment Area: CENTRAL								
JOHNSON WAY								
NEW SALT RIVER RD			550	2				
Assessment Area: DOWNTOWN								
AQUATIC CENTER				2				
HIGHWAY 54			300	2				
LEAVETTE AVENUE			160	2				
MYERS								
NEW BEVILLE DRIVE			530	2				
OLD WALNUT			200	2				
PARKLAND MANOR APARTMENTS								
WALNUT PARK			160	2				
WHITE STREET			160	2				
Assessment Area: EAST								
BOAT STORE								
HIGHWAY 1214			220	2				
MEADOW BROOK			150	2				
Assessment Area: NORTH								
GOFF INDUSTRIAL PARK			80	2				
MTD			360	2				
RADIO STATION			160	2				
TRIM MASTERS			380	2				
Assessment Area: RESIDENTIAL								
ASHTON WAY								
JAMES ST			650	3				
ONEAL SMITH			200	2				
SUNSET DR								
Assessment Area: SOUTHWEST								
HIGH SCHOOL				1				
Y CONVENIENCE STORE				1				
Assessment Area: WEST								
BRITT STREET			160	2				
CAMERON DR								
CROSSRIDGE			160	2				
NEW LILAC ROAD			450	2				

WRIS Asset Inventory Report

KY0022934 - Leitchfield Utilities Commission

Rating Code	Condition Rating	Performance Rating	Priority Rating
0			Not a priority
1	New or Excellent - None or minor defects.	Exceeds/Meets all performance targets.	It would be nice to have.
2	Good - Defects that have not begun to deteriorate.	Minor performance deficiencies.	Improved system operations & maintenance (O&M) efficiency.
3	Fair - Moderate defects that will continue to deteriorate.	Considerable performance deficiencies.	Internal safety concern or public nuisance.
4	Poor - Severe defects that will collapse/break in near future.	Major performance deficiencies.	Potential public health, safety, or environmental concern.
5	Inoperable - Defects need immediate attention.	Fails to meet performance targets.	Existing threat to public health, safety, or environment.

Sewer Treatment Plants

STP Name	Design Capacity (MGD)	Date Constructed	Major Expansion Date	Condition ID	Performance ID	Priority ID	WRIS PNum
LEITCHFIELD WWTP	2.00000000	06/01/1988	06/01/2001	3	4	4	SX21085013

Treatment Plant Components:

--